



88 Empire Drive • St. Paul, Minnesota • 55103
(651) 642-1150 • fax (651) 642-1239

VOC Content Test Certificate

August 25, 2020

Supplier: Hilti Entwicklungsgesellschaft mbH
BU Chemicals
Hiltistrasse 6
86916 Kaufering
GERMANY

Sample Description: Hilti CFS-F FX

Date Tested: August 20, 2020

Test Method: SCAQMD method 304-91 "Determination of Volatile Organic Compounds (VOC) in Various Materials" as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168. The values also comply with the requirements of EPA test method #24.

Test Data:

Specification	Product
LEED 4.1 Low-Emitting Materials – Adhesives and Sealants	CFS-F FX
Green Building Council of Australia Green Star Office Design 3.0, IEQ-13 Green Star Office Design 2.0, IEQ-13 Green Star Office Interiors 1.1, IEQ-11	
Foam Sealant VOC Limit: 250 g/L	Product contains: 26 g/L of VOC

Tom Barrett
Vice President/Strategic Analytical Services